Unit 30 | Fern Close | Pen-Y-Fan Ind Est | Oakdale | Gwent | NP11 3EH | UK
Tel: +44 (0) 1495 236260 wales@nsf.org | www.nsf.org

TEST REPORT

Customer: C0883715

ONUR EK PARÇALARI VE PLASTIK BORU SAN. TIC. LTD. STI
Teyfikbey Mah. Emrullah Efendi
Cad. No:21/C Sefaköy-Küçükçekmece
Istanbul
Turkey

Facility: C0883716

ONUR EK PARÇALARI VE PLASTIK BORU SAN.TIC.LTD.STI.
Teyfikbey Mah. Emrullah Efendi
Cad. No:21/C Sefaköy-Küçükçekmece
, TR-34
Turkey

Result	Audit testing was carried out on this material in accordance with the letter from WRAS dated 19/01/26. Previous approval number 2009509. This product has satisfied the relevant clauses set out in BS 6920: Part 1: 2014 "Specification" for the tests detailed in this report.
Customer Name	ONUR EK PARÇALARI VE PLASTIK BORU SAN. TIC. LTD. STI
Product	Yuhwa rp 2400 Green PPR Fitting
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00551906
Work Order Number	W1038779

Thank you for having your product tested by NSF Wales Ltd.

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

Report Date 25-MAR-2026

Report Authorisation

Jessica Davey - Senior Scientist Labs

UKAS TESTING
0626

This report is issued in accordance with the laboratory accreditation requirements of the ISO/IEC 17025:2017 Standard. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This report shall not be reproduced, except in its entirety, without the written approval of NSF Wales Ltd. This report does not represent NSF Certification or authorisation to use the NSF Mark. Authorisation to use the NSF Mark is limited to products appearing in the Company's Official NSF Listing (www.nsf.org). The results relate only to those items tested, in the condition received at the laboratory.

Result Summary Section

Test	Result
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 23°C	Pass
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 85°C	Pass
Extraction of substances that may be of concern to public health BS 6920: Part 1: 2014, Clause 7 - 23°C	Pass
Extraction of substances that may be of concern to public health BS 6920: Part 1: 2014, Clause 7 - 85°C	Pass

Sample Details

Date of Receipt of Application Form	24/SEPTEMBER/2025
Date of Receipt of Product for Test	11/DECEMBER/2025
Front Cover Test Description	Audit testing was carried out on this material in accordance with the letter from WRAS dated 19/01/26. Previous approval number 2009509.
Product *	Yuhwa rp 2400 Green PPR Fitting
Nature of Material *	PPR
Date Test Sample Manufactured *	16/SEPTEMBER/2025
Receipt Conditions	Good Condition
Receipt Packaging	CLEAR PLASTIC BAGS
Product Manufacturer *	Onur Ek Parcalari Ve Plastik Boru San Tic Ltd Sti
Product Manufacturing Site *	Turkey
Tradename and Reference of Product *	Yuhwa rp 2400 Green PPR Fitting
Method of Manufacture *	Extrusion
Typical Use of the Product *	Conveyance of potable water
Material Manufacturer *	Korea Petrochemical Ind Co Ltd
Tradename and Reference of Material *	Yuhwa rp2400
Material Manufacturing Site *	Korea
Nature of Product *	Tee
Sampling Procedure *	Random selection from stock
Address of Product Manufacturer *	Teyfikbey Mah. Emrullah Efendi Cad. No:21/C Sefaköy-Küçükçekmece / ISTANBUL
Submitting Organization *	Onur Ek Parcalari Ve Plastik Boru San Tic Ltd Sti

* denotes customer supplied information

Sample Preparation

Description/Appearance of the product	Green, opaque, rigid fitting
Length	60.4 mm
Inner diameter	23.9 mm
Outer diameter	33.4 mm
Surface area of one article	15067.1 mm2
Number of articles constituting a sample	1
Surface area for test	15067.1 mm2
Calibration mark of test container	1 L
Storage Conditions	As in BS 6920: Part 2: Section 2.1: Clause 5.2

Job Attachments:



Photo 1

Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 23°C

Methodology: BS 6920: Part 2: Section 2.2 and in-house method PROC/MAT 004 and 006.

Date Leaching Test Started: 2-MAR-2026

First Extract - Chlorinated Test Water

Panellist	Odour Descriptor	Flavour Descriptor	Flavour Dilution Number
1	None	None	1
2	None	None	1
3	None	None	1

First Extract - Chlorine Free Test Water

Panellist	Odour Descriptor	Flavour Descriptor	Flavour Dilution Number
1	None	None	1
2	None	None	1
3	None	None	1

On the basis of these results the samples of this product referred to in this report have been found to conform to the requirements of BS 6920: Part 1: 2014, Clause 4.

Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 85°C

Methodology: BS 6920: Part 2: Section 2.2 and in-house method PROC/MAT 004 and 006.

Date Leaching Test Started: 25-FEB-2026

First Extract - Chlorinated Test Water

Panellist	Odour Descriptor	Flavour Descriptor	Flavour Dilution Number
1	None	None	1
2	None	None	1
3	None	None	1

First Extract - Chlorine Free Test Water

Panellist	Odour Descriptor	Flavour Descriptor	Flavour Dilution Number
1	None	None	1
2	None	None	1
3	None	None	1

On the basis of these results the samples of this product referred to in this report have been found to conform to the requirements of BS 6920: Part 1: 2014, Clause 4.

Extraction of substances that may be of concern to public health BS 6920: Part 1: 2014, Clause 7 - 23°C

Methodology: BS 6920: Part 2: Section 2.5 and in-house methods PROC/MAT 004 and PROC/MIC 004.

Date Leaching Test Started: 24-FEB-2026

Cell concentration used: 5×10^{5}

Cell morphology: Confluent growth of elongated cells, some round cells and cell debris. Media orange/pink in colour.

Sample/Control	Cell Morphology	Response
Test Sample	Confluent growth of elongated cells, some round cells and cell debris. Media pink in colour.	Non-Cytotoxic
Blank	Confluent growth of elongated cells, some round cells and cell debris. Media pink in colour.	Non-Cytotoxic
Negative Control	Confluent growth of elongated cells, some round cells and cell debris. Media pink in colour.	Non-Cytotoxic
Positive Control	All cells rounded and mainly still in suspension. Media pink in colour.	Cytotoxic

On the basis of these results the samples of this product referred to in this report have been found to conform to the requirements of BS 6920: Part 1: 2014, Clause 7.

Extraction of substances that may be of concern to public health BS 6920: Part 1: 2014, Clause 7 - 85°C

Methodology: BS 6920: Part 2: Section 2.5 and in-house methods PROC/MAT 004 and PROC/MIC 004.

Date Leaching Test Started: 17-FEB-2026

Cell concentration used: 5×10^{5}

Cell morphology: Confluent growth of elongated cells, some round cells and cell debris. Media orange/pink in colour.

Sample/Control	Cell Morphology	Response
Test Sample	Confluent growth of elongated cells, some round cells and cell debris. Media pink in colour.	Non-Cytotoxic
Blank	Confluent growth of elongated cells, some round cells and cell debris. Media pink in colour.	Non-Cytotoxic
Negative Control	Confluent growth of elongated cells, some round cells and cell debris. Media pink in colour.	Non-Cytotoxic
Positive Control	All cells rounded and mainly still in suspension. Media pink in colour.	Cytotoxic

On the basis of these results the samples of this product referred to in this report have been found to conform to the requirements of BS 6920: Part 1: 2014, Clause 7.

<< Testing Laboratories >>

	Flag	Id	Address
All work performed at: (Unless otherwise specified)	→	NSF_WALES	NSF Wales Ltd. NSF Wales Ltd Unit 30 Fern Close Pen-Y-Fan Industrial Estate Oakdale, Newport NP11 3EH, UK

NOTES

1. This report is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service (UKAS). NSF Wales Ltd is UKAS accredited against ISO/IEC 17025:2017 for testing, laboratory number 0626. For details of the laboratory Schedule of Accreditation please see the UKAS website (www.ukas.com).
2. The laboratory provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes.
3. Reported conformity statements have been applied in line with the decision rule inherent in the applicable testing standard.
4. Test reports utilise the simplified test report format option allowed by ISO/IEC 17025:2017 (reference clause 7.8.1.3). This simplified report does not include all of the information on the report specified by ISO/IEC 17025:2017 (clauses 7.8.2 to 7.8.7) but as stated in the standard this data is held by the laboratory and is available to the client on request.
5. Opinions and interpretations in this report are outside the scope of UKAS Accreditation.
6. The results specified in this report relate only to the sample(s) of the product submitted for testing. Any change in the source or nature of the product or materials used in the product, method of manufacture or application could affect the performance of the product.
7. This test report does not constitute approval or endorsement of the product by either NSF Wales Ltd or its parent companies.
8. The contents of this report are the copyright of NSF Wales Ltd and all rights are reserved. No part of this publication may be reproduced, stored in a retrieval system in any form or by any means electronic, mechanical, photocopying, recording or otherwise, without prior written consent of NSF Wales Ltd.
9. Any queries regarding this report should be addressed to the authorised signatory at NSF Wales Ltd. Copies of reports are retained by NSF Wales Ltd for ten years after issue.
10. Non UKAS accredited tests or tests which have been subcontracted will be identified in the following manner:
    - Tests marked † are not included in the laboratory's ISO 17025 accreditation schedule.
    - Tests marked ‡ have not been performed by NSF Wales Ltd and have been performed at an approved subcontract laboratory.
11. We draw to your attention that reports issued by the accredited test laboratories do not of themselves constitute approval by the Water Regulations Advisory Scheme or the test laboratory. Only a letter from the Scheme, citing a Directory Reference number can be regarded as indicating approval.
12. Materials and products intended for use by public water supply company in the preparation or conveyance of water may need to satisfy more comprehensive toxicological requirements as specified by the Drinking Water Inspectorate. These additional requirements are necessary to ensure water Company usage compiles with Regulation 31 of the Water Supply (Water Quality) Regulations 2010.